

# Highlands Elementary School



**LA Testing**  
 5431 Industrial Drive, Huntington Beach, CA 92649  
 Phone/Fax: (714) 828-4999 / (714) 828-4944  
<http://www.LATesting.com>    [nlab@latesting.com](mailto:nlab@latesting.com)

LA Testing Order: 332316224  
 CustomerID: WEST60  
 CustomerPO:  
 ProjectID:

Attn: **David A Christy**  
**Western Environmental & Safety Tech.**  
**7676 Hazard Center Drive**  
**Suite 500**  
**San Diego, CA 92108**

Phone: (858) 271-1842  
 Fax: (858) 271-1856  
 Received: 9/18/2023 10:00 AM  
 Collected: 9/12/2023

Project: **LA MESA SCHOOLS**

## Analytical Results

Client Sample Description		HE-03	Collected:	10/10/2023	Lab ID:	332317738-0016	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
RM 2 FOUNTAIN - FD							
<b>METALS</b>							
200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-04	Collected:	10/10/2023	Lab ID:	332317738-0017	
RM 9 FOUNTAIN - FD							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-05	Collected:	10/10/2023	Lab ID:	332317738-0018	
RM 10 FOUNTAIN - FD							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-06	Collected:	10/10/2023	Lab ID:	332317738-0019	
RM 17 FOUNTAIN - FD							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	1.66	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-07	Collected:	10/10/2023	Lab ID:	332317738-0020	
RM 18 FOUNTAIN - FD							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	5.90	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-01	Collected:	10/10/2023	Lab ID:	332317738-0014	
RM 1 FOUNTAIN - FD							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	1.38	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-02	Collected:	10/10/2023	Lab ID:	332317738-0015	
RM 1 FOUNTAIN - FLUSH							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023 XL
Client Sample Description		HE-08	Collected:	10/10/2023	Lab ID:	332317738-0021	
RM 18 FOUNTAIN - FLUSH							
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
<b>METALS</b>							
200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023 XL