

La Mesa Dale Elementary School



LA Testing
 5431 Industrial Drive, Huntington Beach, CA 92649
 Phone/Fax: (714) 828-4999 / (714) 828-4944
<http://www.LATesting.com> nlab@lateesting.com

LA Testing Order:	332316224
CustomerID:	WEST60
CustomerPO:	
ProjectID:	

Attn: **David A Christy**
Western Environmental & Safety Tech.
7676 Hazard Center Drive
Suite 500
San Diego, CA 92108

Phone: (858) 271-1842
 Fax: (858) 271-1856
 Received: 9/18/2023 10:00 AM
 Collected: 9/12/2023

Project: **LA MESA SCHOOLS**

Analytical Results

Client Sample Description LMD-01 *Collected:* 10/14/2023 *Lab ID:* 332318086-0001
 RM 15 - FOUNTAIN - FD

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	2.15	1.00	µg/L	10/17/2023 XL	10/18/2023 XL

Client Sample Description LMD-02 *Collected:* 10/14/2023 *Lab ID:* 332318086-0002
 RM 25 - FOUNTAIN - FD

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/17/2023 XL	10/18/2023 XL

Client Sample Description LMD-03 *Collected:* 10/14/2023 *Lab ID:* 332318086-0003
 RM 25 FOUNTAIN - FLUSH

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/17/2023 XL	10/18/2023 XL

Client Sample Description LMD-04 *Collected:* 10/14/2023 *Lab ID:* 332318086-0004
 EXT FOUNTAIN @ RM 8 - FD (LEFT)

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/17/2023 XL	10/18/2023 XL

Client Sample Description LMD-05 *Collected:* 10/14/2023 *Lab ID:* 332318086-0005
 EXT FOUNTAIN @ ADMIN - FD (RIGHT)

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/17/2023 XL	10/18/2023 XL