

La Presa Elementary School



LA Testing
 5431 Industrial Drive, Huntington Beach, CA 92649
 Phone/Fax: (714) 828-4999 / (714) 828-4944
<http://www.LATesting.com> nlab@lateesting.com

LA Testing Order: 332316224
 CustomerID: WEST60
 CustomerPO:
 ProjectID:

Attn: **David A Christy**
Western Environmental & Safety Tech.
7676 Hazard Center Drive
Suite 500
San Diego, CA 92108

Phone: (858) 271-1842
 Fax: (858) 271-1856
 Received: 9/18/2023 10:00 AM
 Collected: 9/12/2023

Project: **LA MESA SCHOOLS**

Analytical Results

<i>Client Sample Description</i> LP-01 RM K1 FOUNTAIN-F.D	<i>Collected:</i>	<i>Lab ID:</i>	332317743-0006
--	-------------------	----------------	----------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
---------------	------------------	---------------	-----------	--------------	--------------------------------	------------------------------------

METALS

200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023	XL
-------	------	-------	------	------	------------	----	------------	----

<i>Client Sample Description</i> LP-02 RM 1- FOUNTAIN-F.D	<i>Collected:</i>	<i>Lab ID:</i>	332317743-0007
--	-------------------	----------------	----------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
---------------	------------------	---------------	-----------	--------------	--------------------------------	------------------------------------

METALS

200.8	Lead	4.81	1.00	µg/L	10/11/2023	XL	10/12/2023	XL
-------	------	------	------	------	------------	----	------------	----

<i>Client Sample Description</i> LP-03 RM 5- FOUNTAIN-F.D	<i>Collected:</i>	<i>Lab ID:</i>	332317743-0008
--	-------------------	----------------	----------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
---------------	------------------	---------------	-----------	--------------	--------------------------------	------------------------------------

METALS

200.8	Lead	2.07	1.00	µg/L	10/11/2023	XL	10/12/2023	XL
-------	------	------	------	------	------------	----	------------	----

<i>Client Sample Description</i> LP-04 RM 18-FOUNTAIN-F.D	<i>Collected:</i>	<i>Lab ID:</i>	332317743-0009
--	-------------------	----------------	----------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
---------------	------------------	---------------	-----------	--------------	--------------------------------	------------------------------------

METALS

200.8	Lead	3.29	1.00	µg/L	10/11/2023	XL	10/12/2023	XL
-------	------	------	------	------	------------	----	------------	----

<i>Client Sample Description</i> LP-05 RM 18- FOUNTAIN-FLUSH	<i>Collected:</i>	<i>Lab ID:</i>	332317743-0010
---	-------------------	----------------	----------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
---------------	------------------	---------------	-----------	--------------	--------------------------------	------------------------------------

METALS

200.8	Lead	<1.00	1.00	µg/L	10/11/2023	XL	10/12/2023	XL
-------	------	-------	------	------	------------	----	------------	----