

Loma Elementary School



LA Testing
 5431 Industrial Drive, Huntington Beach, CA 92649
 Phone/Fax: (714) 828-4999 / (714) 828-4944
<http://www.LATesting.com> nlab@latesting.com

LA Testing Order: 332316224
 CustomerID: WEST60
 CustomerPO:
 ProjectID:

Attn: **David A Christy**
Western Environmental & Safety Tech.
7676 Hazard Center Drive
Suite 500
San Diego, CA 92108

Phone: (858) 271-1842
 Fax: (858) 271-1856
 Received: 9/18/2023 10:00 AM
 Collected: 9/12/2023

Project: **LA MESA SCHOOLS**

Analytical Results

Client Sample Description L-03 LIBRARY - FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0011

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-04 RM 13 - FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0012

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	2.33	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-05 RM 13 - FOUNTAIN - FLUSH **Collected:** 10/9/2023 **Lab ID:** 332317740-0013

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-06 RM 9 - FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0014

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-07 RM 7 - FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0015

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-01 RM P19 FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0009

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	<1.00	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-02 RM 15 - FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0010

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	2.07	1.00	µg/L	10/10/2023 XL	10/11/2023 XL

Client Sample Description L-08 EXT. BLDG. 8 FOUNTAIN - F.D. **Collected:** 10/9/2023 **Lab ID:** 332317740-0016

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Lead	1.66	1.00	µg/L	10/10/2023 XL	10/11/2023 XL