

Maryland Elementary School



LA Testing
 5431 Industrial Drive, Huntington Beach, CA 92649
 Phone/Fax: (714) 828-4999 / (714) 828-4944
<http://www.LATesting.com> nlab@lateesting.com

LA Testing Order: 332316224
 CustomerID: WEST60
 CustomerPO:
 ProjectID:

Attn: **David A Christy**
Western Environmental & Safety Tech.
7676 Hazard Center Drive
Suite 500
San Diego, CA 92108

Phone: (858) 271-1842
 Fax: (858) 271-1856
 Received: 9/18/2023 10:00 AM
 Collected: 9/12/2023

Project: **LA MESA SCHOOLS**

Analytical Results

Client Sample Description M-01
 RM 1 - FOUNTAIN - FD *Collected:* 10/14/2023 *Lab ID:* 332318086-0014

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----	-------	---------------------	-------------------------

METALS

200.8	Lead	1.85	1.00	µg/L	10/17/2023 XL	10/18/2023 XL
-------	------	------	------	------	---------------	---------------

Client Sample Description M-02
 RM 6 - FOUNTAIN - FD *Collected:* 10/14/2023 *Lab ID:* 332318086-0015

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----	-------	---------------------	-------------------------

METALS

200.8	Lead	2.09	1.00	µg/L	10/17/2023 XL	10/18/2023 XL
-------	------	------	------	------	---------------	---------------

Client Sample Description M-03
 RM 8 - FOUNTAIN - FD *Collected:* 10/14/2023 *Lab ID:* 332318086-0016

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----	-------	---------------------	-------------------------

METALS

200.8	Lead	<1.00	1.00	µg/L	10/17/2023 XL	10/18/2023 XL
-------	------	-------	------	------	---------------	---------------

Client Sample Description M-04
 RM 8 - FOUNTAIN - FLUSH *Collected:* 10/14/2023 *Lab ID:* 332318086-0017

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----	-------	---------------------	-------------------------

METALS

200.8	Lead	<1.00	1.00	µg/L	10/17/2023 XL	10/18/2023 XL
-------	------	-------	------	------	---------------	---------------

Client Sample Description M-05
 EXT FOUNTAIN @ BLDG 7 - FD (RIGHT) *Collected:* 10/14/2023 *Lab ID:* 332318086-0018

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----	-------	---------------------	-------------------------

METALS

200.8	Lead	1.62	1.00	µg/L	10/17/2023 XL	10/18/2023 XL
-------	------	------	------	------	---------------	---------------