

Parkway Middle School



LA Testing

5431 Industrial Drive, Huntington Beach, CA 92649
 Phone/Fax: (714) 828-4999 / (714) 828-4944
<http://www.LATesting.com> hblab@latesting.com

LA Testing Order: 332316224
 CustomerID: WEST60
 CustomerPO:
 ProjectID:

Attn: **David A Christy**
Western Environmental & Safety Tech.
7676 Hazard Center Drive
Suite 500
San Diego, CA 92108

Phone: (858) 271-1842
 Fax: (858) 271-1856
 Received: 9/18/2023 10:00 AM
 Collected: 9/12/2023

Project: **LA MESA SCHOOLS**

Analytical Results

Client Sample Description	PM-01 RM 7 SINK FD	Collected:	9/12/2023	Lab ID:	332316224-0001
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.72	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-02 RM 16 SINK FD	Collected:	9/12/2023	Lab ID:	332316224-0002
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.87	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-03 RM 21 SINK FD	Collected:	9/12/2023	Lab ID:	332316224-0003
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.49	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-04 RM 21 SINK FLUSH	Collected:	9/12/2023	Lab ID:	332316224-0004
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.43	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-05 RM 5 SINK FD	Collected:	9/12/2023	Lab ID:	332316224-0005
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	<1.00	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-06 RM 30 SINK FD	Collected:	9/12/2023	Lab ID:	332316224-0006
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.13	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-07 GAME ROOM SINK FD	Collected:	9/12/2023	Lab ID:	332316224-0007
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.3	1.00 µg/L	9/18/2023 XL	9/19/2023 XL
Client Sample Description	PM-08 GAME ROOM SINK FLUSH	Collected:	9/12/2023	Lab ID:	332316224-0008
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.02	1.00 µg/L	9/18/2023 XL	9/19/2023 XL